

Water Analysis Report



Regional Water Analysis Laboratory

(An NABL Accredited Laboratory)

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005



TC-12993


Report No.: C/VNS/11/2025/0000014	Date: 20.11.2025	No. of Pages: 1	
Customer Details			
Office Name and Address	Silver Grove School, Sewapuri, Uparwar, Varanasi		
Ref. Letter No. & Date	NA	Date: 17.11.2025	
Basic Details of Sample			
District	Varanasi	Block	Sewapuri
Gram Panchayat	Uparwar	Village	Uparwar
Habitation	NA	Location	School Campus, Uparwar, Sewapuri
Water Source	Submersible	Sample Code	VNS/NOV25/00014
Quantity of Sample	1000 mL (Normal)	Sampling date	15.11.2025
Sample Received Date	15.11.2025	S. collected by	Mr Aditya Yadav
Sampling Method Used	NA	Sample Depositor	Mr Aditya Yadav
Analysis Start Date	18.11.2025	Analysis Completion date	18.11.2025

Temperature- 24.6°C, Humidity- 55%

Test Result					
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.69	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	2.18	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	399.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	20.69	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	343.33	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	253.33	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	30.21	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	42.72	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	16.83	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	10.95	45	No relaxation	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.64	1.0	1.5	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
12	Iron (as Fe), mg/l	BDL (<0.1)	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

- Note:**
- This certificate refers only to the particular sample(s) submitted for analysis.
 - This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 - The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 - Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
 - Parameters above Permissible Limit are written in **bold**.
 - Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 - Sample is not Collected by Lab.


ABHAY KUMAR PANDEY
 (Report prepared by)


VIVEK KUMAR
 (Report Reviewed & Authorized by)

Laboratory Contact detail: Email: aroupjn@gmail.com Mobile No.:8400202287

*****END OF THE ANALYSIS REPORT*****

